

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-1591:130 Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: Edwards Systems Technology, 6411 Parkland Dr., Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Models 2251F and 2251TF photoelectric smoke detector. Model 2251TF employs an integral supplemental heat sensor. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors when used in conjunction with listee's listed Models B210LP, B501, and B501BH bases (CSFM Listing No. 7300-1591:119) and separately listed compatible fire alarm control units.

XLF: 7272-1209:160

NOTE: Formerly 7272-1388:226

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager